



Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
EN-ST-000120	21-02-2013	20-02-2017

Subject matter of Certificate:

**Alarm transmission equipment
IRIS Touch 600**

Owner of Certificate:

**Chiron Security Communications Ltd.
Wyvols Court, Swallowfield
GB-RG7 IWY READING**

Basis for certification:

**EN 50136-1-1:1998 + A1:2001
EN 50136-1-5:2008
EN 50136-2-1:1998 + A1:2001**

Use, the product disposes of the following parameters:

Wireless alarm transmission equipment , ATS 2 (GSM), ATS 5 (GPRS)

*The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in test report:*

STE 08/0225, 0285

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.

VdS Schadenverhütung GmbH
Zertifizierungsstelle
Amsterdamer Str. 174
D-50735 Köln

a company of the Gesamtverband
der Deutschen Versicherungswirt-
schaft e.V. (GDV)

is accredited according to DIN EN
ISO/IEC 17025 for testing and
according to
DIN EN 45011 for certification for
fire protection and security
systems by the Deutschen
Akkreditierungsstelle Technik
(DATech)



DAT-ZE-005/92

Date: 21-02-2013

Managing director

Head of certification body



Enclosure 1

Sheet 1

To Certificate No.: EN-ST-000120

Date : 21-02-2013

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>IRIS Dialler (GSM/GPRS) without enclosure in combination with receiving software "Polling Engine". (The EN security grade depends on the alarm system where the IRIS Dialler is build in.)</p> <p>The IRIS 6xx Dialler series is designed to be mounted in the following intruder alarm systems (by an installer):</p> <ul style="list-style-type: none">- Honeywell Galaxy- Texecom Premier	IRIS 600 Touch		



To Certificate No.: EN-ST-000120

Date : 21-02-2013

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual:			
- IRIS Touch 600 Range Dialler Installation Manual, Version 1.4		12/2012	21
- IRIS Management Suite Technical Guide for the User, Version 1.7E		10.07.2008	40
Technical Documents:			
- Touch 6xx Series Packaging Instructions & Drawings	Packaging-024	04.12.2012	21
- Layout drawings	T600-3	04.12.2012	8
- Circuit diagram	T600 (GPRS) V3-0	04.12.2012	5
- Bill of materials	IRIS Touch 600	11.12.2012	8



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000120

Date : 21-02-2013

Instructions for the application of the approval component/system (see enclosure 1):

The IRIS Dialler and the Polling Engine have to be programmed in such a way that they comply with EN 50136-1-1:1998 + A1:2001, EN 50136-2-1:1998 + A1:2001 and EN50136-1-5:2008.